

NOTES

- Meter socket to be installed in a location accessible to meter readers.
- 2. Meter socket to be so designed that incoming line ends cannot be accessed through any unsealed part of the meter socket.

 1700 max (900 min)
 WHERE INSTALLED ON EXTERNAL GUARDWALL

 610 min

METER SOCKET INSTALLATION UNDERGROUND SERVICE